

Cassilis Water Supply
Sample Test Results

Sample Date - 21/01/2025

	Sample Point 1 -Cassilis Community Centre - Buccleugh St Cassilis			Sample Point 2 - No. 5-7 Buccleugh St Cassilis			Sample Point 3 - No. 37 Coolah Road Cassilis			Sample Point 4 -No 5 Scott St Cassilis			Sample Point 5 - No. 26 Nbransome St Cassilis		
	Calcium (mg/L)	Magnesium (mg/L)	Total Hardness as CaCO3 (mg/L)	Calcium (mg/L)	Magnesium (mg/L)	Total Hardness as CaCO3 (mg/L)	Calcium (mg/L)	Magnesium (mg/L)	Total Hardness as CaCO3 (mg/L)	Calcium (mg/L)	Magnesium (mg/L)	Total Hardness as CaCO3 (mg/L)	Calcium (mg/L)	Magnesium (mg/L)	Total Hardness as CaCO3 (mg/L)
Water Main - Before Flushing	47.00	33.77	256.40	45.20	35.03	257.10	46.30	36.42	265.60	46.50	35.49	262.30	44.60	34.52	253.50
Water Main - After Flushing	46.50	35.20	261.40	46.60	35.99	264.60	46.00	35.81	262.30	47.80	34.66	262.10	47.10	34.64	260.30
Near by Private Property- Before Flushing	44.70	33.74	250.60	45.30	34.87	256.70	42.70	34.97	250.60	44.80	35.04	256.20	43.60	35.67	255.80
Near by Private Property- After Flushing	46.90	34.98	261.20	45.50	33.14	250.10	47.00	35.01	261.50	45.20	35.52	259.10	46.70	35.39	262.30

Australian Drinking Water Guideline Limit for Total Hardness as CaCO3 is 200 mg/L