

Merriwa Water Supply
Sample Test Results

Sample Date - 18/03/2025

	Sample Point 1 -Cnr of Dutton St and Mackenzie St (West) Merriwa- (106 Mackenzie St)			Sample Point 2 - Mackenzie St (East) near Hospital -(32 Mackenzie St Merriwa)			Sample Point 3 - Marquet St (north) Merriwa - (15 Marquet St Merriwa)			Sample Point 4 -Prices Lane Merriwa (13 Prices Lane Merriwa)			Sample Point 5 -Bow St (south) Merriwa (94 Bow St Merriwa)		
	Calcium (mg/L)	Magnesium (mg/L)	Total Hardness as CaCO ₃ (mg/L)	Calcium (mg/L)	Magnesium (mg/L)	Total Hardness as CaCO ₃ (mg/L)	Calcium (mg/L)	Magnesium (mg/L)	Total Hardness as CaCO ₃ (mg/L)	Calcium (mg/L)	Magnesium (mg/L)	Total Hardness as CaCO ₃ (mg/L)	Calcium (mg/L)	Magnesium (mg/L)	Total Hardness as CaCO ₃ (mg/L)
Water Main - Before Flushing	28.10	14.10	128.20	29.20	14.62	133.10	29.00	15.01	134.20	29.20	15.25	135.70	28.60	15.15	133.80
Water Main - After Flushing	28.40	14.12	129.10	28.20	14.74	131.10	29.00	14.57	132.40	29.00	14.88	133.70	27.90	14.67	130.10
Private Property- Before Flushing	29.50	15.20	136.30	29.20	14.70	133.40	28.60	14.68	131.90	29.00	15.43	136.00	28.70	15.21	134.30
Private Property- After Flushing	28.80	14.37	131.10	28.90	14.85	133.30	29.10	14.44	132.10	29.30	15.59	137.40	28.40	14.58	131.00

Australian Drinking Water Guideline Limit for Total Hardness as CaCO₃ is 200 mg/L